

Approval Number: 1709505
Test Report: MAT/LAB 886L



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

21st June 2017

Gapi S.p.a
Via Molinaretti, 2,
I-24060,
Castelli Calepio (BG),
Italy

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
CONSECUTIVE MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE) - MATERIAL ONLY.

5295

'PTFE FE 1000'. White coloured, compression moulded PTFE material. For use with water up to 85°C.

APPROVAL NUMBER: 1709505

APPROVAL HOLDER: GAPI S.P.A

This is a re-approval of 1208510 which is valid between August 2012 and August 2017.

The Scheme reserves the right to review approval.

Approval 1709505 is valid between September 2017 and September 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, 'Materials which have passed full tests of effect on water quality'.

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

Approval Number: 1704562
Test Report: MAT/LAB 167M



21st June 2017

Gapi S.p.a
Via Molinaretti, 2,
I-24060,
Castelli Calepio (BG),
Italy

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE) - COMPONENTS.

5294

'PTFE FE 1000 Ring'. White coloured, extruded PTFE washer. For use with water up to 85°C.

APPROVAL NUMBER: 1704562
APPROVAL HOLDER: GAPI S.P.A

The Scheme reserves the right to review approval.
Approval 1704562 is valid between April 2017 and April 2022

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme